

B.A. Construction Services, LLC.

8 Airport Park Boulevard
Latham, NY 12110
Ph : 518-785-3005

RFI

To: Jere Tatich
Elan Planning & Design, Inc.
18 Division Street, Rm 304
Saratoga Springs, NY 12866
Ph: (518) 306-3702 Fax: (518) 226-0469

RFI #: HV01-11
Date: 5/15/2008
Job: 07-20-2046 Hoosic Valley Central School
Phone:

CC: Thomas Kenney (CS Arch, P.C.)

Subject: HV01-11 Field "E" Elevations

Drawing: DWG CL - 103

Spec Section:

Cost Impact: None

Schedule Impact: None

Request:

Date Required: 5/22/2008

1. Field "E" high point in field is shown as 391.60, Ends shown at 391.30 slope is shown as 1/2 % , it actually works out to less than 1/4 % .
2. Same field Highpoint in center is 391.60 middle contour is 391.00 , sideline East is 391.50 . Water would pool in field.

Requested by: Bruce Boice
B.A. Construction Services LLC

Response:

1. The statements in request #1 are correct. 1/4% is an acceptable slope for the length of the field. The drainage will take place across the width of the field.
2. The revised edge of field elevations shall be 390.34 at the east edge. This will provide a 1.1% slope from the centerline to the east sideline.

Answered by: Ryan Berry
Elan Planning & Design, Inc.

Answered date: May 21, 2008