

**B.A. Construction Services, LLC.**

8 Airport Park Boulevard  
Latham, NY 12110  
Ph : 518-785-3005

***RFI***

**To:** Thomas Field  
Clark Engineering, P.C.  
20 Shaker Road  
New Lebanon, NY 12125  
Ph: (518) 794-8613 Fax: (518) 766-5663

**RFI #:** HV01-12  
**Date:** 5/22/2008  
**Job:** 07-20-2046 Hoosic Valley Central School  
**Phone:**

**CC:** Thomas Kenney (CS Arch, P.C.), Melissa Renkawitz (CS Arch, P.C.), Carmen Goodwin (CS Arch, P.C.), Ann Clark (Clark Engineering, P.C.)

**Subject:** Existing Sewer Line Resolution

**Drawing:** HS C-100  
**Cost Impact:** None

**Spec Section:**  
**Schedule Impact:** None

**Request:** **Date Required:** 5/23/2008

In order to allow footing installation to continue, suggest leaving existing sewer line which is highlighted in place. Footings would be poured over line and pipe would be grouted when we remove line. We will give a credit of \$200.00 to leave 70' of line in place. Grouting would be by other contractor.

**Requested by:** Letha Price  
B.A. Construction Services LLC

**Response:**

THOMAS FIELD-CLARK ENGINEERING RESPONSE: This is acceptable however the credit is not.

THOMAS KENNEY-CS ARCH RESPONSE: I agree w/Tom's comment, we are trying to accomodate the schedule and the contractor's work sequence in the best interests of the project and we find the credit quite unacceptable.

**Answered by:** Thomas Field  
Clark Engineering, P.C.

**Answered date:** May 22, 2008