

B.A. Construction Services, LLC.

8 Airport Park Boulevard

Latham, NY 12110

Ph : 518-785-3005

*RFI*

**To:** Thomas Field  
Clark Engineering, P.C.  
20 Shaker Road  
New Lebanon, NY 12125  
Ph: (518) 794-8613 Fax: (518) 766-5663

**RFI #:** HV01-14  
**Date:** 6/12/2008  
**Job:** 07-20-2046 Hoosic Valley Central School  
**Phone:**

**CC:** Thomas Kenney (CS Arch, P.C.), Melissa Renkawitz (CS Arch, P.C.), Carmen Goodwin (CS Arch, P.C.)

**Subject:** Stormceptor Inverts

**Drawing:** HS C-104 - High and Middle School Site  
Utility Plan

**Spec Section:**

**Cost Impact:** None

**Schedule Impact:** None

**Request:**

**Date Required:** 6/16/2008

DWG C-104 - Please provide stormceptor inverts which are covered by overlaid detail.

**Requested by:** Letha Price  
B.A. Construction Services LLC

**Response:**

Note reads: 10 Storm Chambers  
Bottom Elevation = 385.50

**Answered by:** Thomas Field  
Clark Engineering, P.C.

**Answered date:** June 20, 2008