

B.A. Construction Services, LLC.

8 Airport Park Boulevard

Latham, NY 12110

Ph : 518-785-3005

RFI

To: Thomas Field
Clark Engineering, P.C.
20 Shaker Road
New Lebanon, NY 12125
Ph: (518) 794-8613 Fax: (518) 766-5663

RFI #: HV01-17
Date: 6/20/2008
Job: 07-20-2046 Hoosic Valley Central School
Phone:

CC: Thomas Kenney (CS Arch, P.C.), Carmen Goodwin (CS Arch, P.C.), Melissa Renkawitz (CS Arch, P.C.)

Subject: Perforated Drain Pipe Missing Detail

Drawing:

Spec Section:

Cost Impact: None

Schedule Impact: None

Request:

Date Required: 6/23/2008

There is no detail shown for installation of 12" and 15" perforated drain pipe.

Requested by: Letha Price
B.A. Construction Services LLC

Response:

The perforated storm pipe is to be installed per detail 5/C-203 which is for plastic storm and sanitary pipe and ductile iron water pipe.

Answered by: Thomas Field
Clark Engineering, P.C.

Answered date: June 23, 2008