

B.A. Construction Services, LLC.

8 Airport Park Boulevard

Latham, NY 12110

Ph : 518-785-3005

*RFI*

**To:** Thomas Field  
Clark Engineering, P.C.  
20 Shaker Road  
New Lebanon, NY 12125  
Ph: (518) 794-8613 Fax: (518) 766-5663

**RFI #:** HV01-18  
**Date:** 6/25/2008  
**Job:** 07-20-2046 Hoosic Valley Central School  
**Phone:**

**CC:** Thomas Kenney (CS Arch, P.C.), Jere Tatich (Elan Planning & Design, Inc.), Ryan Berry (Elan Planning & Design, Inc.)

**Subject:** 12" Perforated Pipe Installation Clarification

**Drawing:** HS C-203 - Site Details

**Spec Section:**

**Cost Impact:** None

**Schedule Impact:** None

**Request:**

**Date Required: 6/30/2008**

This is to clarify that 12" perforated pipe is installed under new track at the South West corner per detail 5/C-203 per RFI Response HV01-17.

**Requested by:** Letha Price  
B.A. Construction Services LLC

**Response:**

Perforated storm sewers should be installed per Detail 5/C-203. However, the pipe section from CB-W6 to CB-W5 should not be perforated.

**Answered by:** Thomas Field  
Clark Engineering, P.C.

**Answered date:** June 25, 2008