

BA Construction Services, LLC.

8 Airport Park Boulevard

Latham, NY 12110

Ph : 518-785-3005

RFI

To: Thomas Field
Clark Engineering, P.C.
20 Shaker Road
New Lebanon, NY 12125
Ph: (518) 794-8613 Fax: (518) 766-5663

RFI #: HV01-29
Date: 9/23/2008
Job: 07-20-2046 Hoosic Valley Central School
Phone:

CC: Thomas Kenney (CS Arch, P.C.), Ryan Berry (Elan Planning & Design, Inc.)

Subject: Silt Saver Required by SWPP Report

Drawing:

Spec Section:

Cost Impact: None

Schedule Impact: None

Request:

Date Required: 9/29/2008

The SWPP reports indicated that silt savers should be installed. Installing these would restrict access for other trades lulls, cement trucks, etc. We have installed filtration fabric to still allow these vehicles access. If an alternate product is available, please advise.

Requested by: Letha Price
B.A. Construction Services LLC

Response:

The filter fabric may be used provided it is installed around the catch basin in accordance with the "New York Standards and Specifications for Erosion and Sediment Control". Placing filter fabric under the grate is not an acceptable alternative.

An alternative product is a filter that hangs down in to the catch basin. Siltsack, Drainguard, Grategator would all be acceptable.

Answered by: Thomas Field
Clark Engineering, P.C.

Answered date: October 21, 2008