

BA Construction Services, LLC.

8 Airport Park Boulevard

Latham, NY 12110

Ph : 518-785-3005

RFI

To: Jere Tatich
Elan Planning & Design, Inc.
18 Division Street, Rm 304
Saratoga Springs, NY 12866
Ph: (518) 306-3702 Fax: (518) 226-0469

RFI #: HV01-30
Date: 9/23/2008
Job: 07-20-2046 Hoosic Valley Central School
Phone:

CC: Thomas Kenney (CS Arch, P.C.), Ryan Berry (Elan Planning & Design, Inc.)

Subject: Ground Hydrant Work Clarification

Drawing:

Spec Section:

Cost Impact: None

Schedule Impact: None

Request:

Date Required: 9/29/2008

We received a letter regarding field clarifications from site meeting on 09/17/2008. Item 3 mentions that ground hydrant is not part of the irrigation system. Is this part of the plumbers work?

Requested by: Letha Price
B.A. Construction Services LLC

Response:

The ground hydrant is a non-potable water source, but will not be cycled through the booster pump. It is not part of the irrigation system and will not be blown out. The decision as to which contract covers this scope of work is the responsibility of the construction manager.

Answered by: Ryan Berry
Elan Planning & Design, Inc.

Answered date: September 25, 2008