

BA Construction Services, LLC.

8 Airport Park Boulevard

Latham, NY 12110

Ph : 518-785-3005

RFI

To: Ryan Berry
Elan Planning & Design, Inc.
18 Division Street, Rm 304
Saratoga Springs, NY 12866
Ph: (518) 306-3702 Fax: (518) 226-0469

RFI #: HV01-34
Date: 10/27/2008
Job: 07-20-2046 Hoosic Valley Central School
Phone:

CC: Bruce Boice (B.A. Construction Services, LLC)

Subject: Jump Pit Sand

Drawing:

Spec Section:

Cost Impact: None

Schedule Impact: None

Request:

Date Required: 10/29/2008

We would like to install the sand for the long jump pits before coating is installed. The specification reads "highly stable bunker type white sand as approved by the engineer or architect". It is our understanding that the first submittal has been rejected due to the angular sands. Could you please provide more information and a source of the material you would like?

Requested by: Letha Price
B.A. Construction Services LLC

Response:

The Material submitted as sand for the Long Jump Pit was rejected for safety reasons. A readily available clean mason sand will be an acceptable product for this use.

Answered by: Ryan Berry
Elan Planning & Design, Inc.

Answered date: October 27, 2008