

B.A. Construction Services, LLC.

8 Airport Park Boulevard
Latham, NY 12110
Ph : 518-785-3005

RFI

To: Thomas Field
Clark Engineering, P.C.
20 Shaker Road
New Lebanon, NY 12125
Ph: (518) 794-8613 Fax: (518) 766-5663

RFI #: 11
Date: 5/9/2008
Job: 07-20-2046 Hoosic Valley Central School
Phone:

CC: Thomas Kenney (CS Arch, P.C.), Bruce Boice

Subject: HV01-5 - Topsoil Height

Drawing: **Spec Section:** 311000
Cost Impact: None **Schedule Impact:** None

Request: **Date Required: 5/20/2008**
Spec Section 311000 3.5 C-1 says to limit topsoil height to 72". The area shown to store topsoil calculates to a storage space of 8000 CY+/- . We anticipate the need to store 14,000 CY of stripped topsoil. Can the pile go higher? Or is there a different location to stockpile?
Requested by: Letha Price
B.A. Construction Services LLC

Response:
Topsoil may be piled higher than 72" provided it is properly protected from erosion with seed and mulch.

Answered by: Thomas Field **Answered date:** May 13, 2008
Clark Engineering, P.C.