

B.A. Construction Services, LLC.

8 Airport Park Boulevard
Latham, NY 12110
Ph : 518-785-3005

RFI

To: Thomas Field
Clark Engineering, P.C.
20 Shaker Road
New Lebanon, NY 12125
Ph: (518) 794-8613 Fax: (518) 766-5663

RFI #: HV01-6
Date: 5/13/2008
Job: 07-20-2046 Hoosic Valley Central School
Phone:

CC: Thomas Kenney (CS Arch, P.C.), Bruce Boice, Melissa Renkawitz (CS Arch, P.C.), Carmen Goodwin (CS Arch, P.C.)

Subject: CB N-1 Location Conflict

Drawing: HS C-104 - High and Middle School Site
Utility Plan

Spec Section:

Cost Impact: None

Schedule Impact: None

Request:

Date Required: 5/21/2008

Dwg HS C-104; Structure CB N-1, if installed where shown, it will conflict with a guy anchor for power pole. This structure will require relocation or the power company will be needed to support pole and reinstall guy anchor. Please advise.

Requested by: B.A. Construction Services LLC

Response:

CB N-1 needs to go where it is. Please coordinate pole support with National Grid.

Answered by: Thomas Field
Clark Engineering, P.C.

Answered date: May 15, 2008